MECHANICAL - Division 23					\
DIVISION 23	SECTION 23 0548	TITLE Vibration Isolation	REVISION DATE 01.2025	REVISION HIGHLIGHTS 2.1 Updated product manufacturers	PREVIOUS VERSION 08.2023
	23 1200	Heat Exchangers	01.2025	1.3.A.2 Updated product manufacturers	03.2020
	23 3319	Sound Attenuators	01.2025	1.3.A Updated product manufacturers	03.2020
	23 3600	HVAC Terminal Units	01.2025	2.2 & 2.3 Revised to emphasize factory certification testing. Eliminated requirement for shipment testing. Sample unit testing and random shipment testing remain options in Part 3.2 TESTING.	03.2020
	23 3713	Air Distribution Devices	01.2025	2.1.F Updated product manufacturers	08.2023